

HIDROÉOLICA GORONA DEL VIENTO

| GRUPOS | POT. NOM. (MW) | PROD. BRUTA (MWh) | CONSUMO EN GENERACIÓN | | PROD. NETA (MWh) | CONSUMO EN PARADA (MWh) | CONSUMO EN BOMBEO (MWh) | SALDO FRONTERA (MWh) | REAJUSTE (NETA-CONS. PARADA-CONS. BOMBEO-SALDO FRONTERA) | | CARGA MÁX. (kW) | CARGA MEDIA (%) | HORAS FUNCIONAM. (Horas) | HORAS DE VIDA | HORAS UTIL. (centes.) | Nº de Acoples |
|-----------------------|----------------|-------------------|-----------------------|-------------|------------------|-------------------------|-------------------------|----------------------|--|-------------|-----------------|-----------------|--------------------------|---------------|-----------------------|---------------|
| | | | (MWh) | (%) | | | | | (MWh) | (%) | | | | | | |
| Eólico 1 | 2,300 | 480,911 | 5,775 | 1,2 | 475,136 | 0,397 | | | | | | 29 | 720,0 | 65.232 | 209,1 | |
| Eólico 2 | 2,300 | 497,486 | 5,967 | 1,2 | 491,519 | 0,221 | | | | | | 30 | 720,0 | 62.551 | 216,3 | |
| Eólico 3 | 2,300 | 517,773 | 6,268 | 1,2 | 511,505 | 0,372 | | | | | | 33 | 690,7 | 64.338 | 225,1 | 1 |
| Eólico 4 | 2,300 | 539,874 | 6,441 | | 533,433 | 0,448 | | | | | | 34 | 689,0 | 65.106 | 234,7 | 2 |
| Eólico 5 | 2,300 | 614,490 | 7,248 | 1,2 | 607,242 | 0,255 | | | | | | 39 | 678,1 | 65.387 | 267,2 | 2 |
| Total Eólica | 11,500 | 2.650,534 | 31,699 | 1,2 | 2.618,835 | 1,693 | | | | | | | | | 230,5 | 5 |
| Turbina 1 | 2,830 | 2,822 | 1,426 | 50,5 | 1,396 | 1,738 | | | | | | 7 | 13,7 | 7.432 | 1,0 | 27 |
| Turbina 2 | 2,830 | 34,945 | 8,572 | 24,5 | 26,373 | 14,097 | | | | | | 12 | 100,7 | 16.785 | 12,3 | 85 |
| Turbina 3 | 2,830 | 148,086 | 16,638 | 11,2 | 131,448 | 9,690 | | | | | | 16 | 331,0 | 31.636 | 52,3 | 57 |
| Turbina 4 | 2,830 | 330,933 | 38,017 | 11,5 | 292,916 | 0,407 | | | | | | 17 | 674,7 | 32.578 | 116,9 | 6 |
| Total Turbinas | 11,320 | 516,786 | 64,654 | 12,5 | 452,132 | 25,933 | | | | | | | | | 45,7 | 175 |
| Bombes | 6,800 | | | | | | 1,293,184 | | | | | | | | | |
| CENTRAL | 22,820 | 3.167,320 | 96,353 | 3,0 | 3.070,967 | 27,626 | 1.293,184 | 1.752,528 | -2,371 | -0,1 | | | | | 138,8 | 180 |

BOMBEO

DEPÓSITOS

| Nombre | Pot. Nom. (MW) | Cons. Bombeo (MWh) | Nombre | Volúmen nominal (dam3) | Volúmen mínimo (dam3) | Volúmen mínimo (%) | Volúmen Real (dam3) | V. Real (%) | V. Req (Dm3) | V. Req (%) | PÉRD./GAN. (dam3) | REPOSICIÓN (dam3) |
|---------------------|----------------|--------------------|----------------|------------------------|-----------------------|--------------------|---------------------|--------------|----------------|---------------|-------------------|-------------------|
| Trafo 1 | 3,400 | 432,635 | Balsa Superior | 380,000 | 31,180 | 8,21 | 111,850 | 29,43 | | | 35,068 | |
| Trafo 2 | 3,400 | 860,549 | Balsa Inferior | 150,000 | 5,830 | 3,89 | 85,367 | 56,91 | | | -38,535 | |
| Total Bombeo | 6,800 | 1.293,184 | Total | 530,000 | 37,010 | 6,98 | 197,216 | 37,21 | 180,000 | 109,56 | -3,468 | |

